

TEST REPORT



Your Ref: _____ Date: **2001-10-12**

Our Ref: **55S01491/KYM/THK** Page: **Page 1 of 6**

DID: **8701219** Fax: **7761568**

(PSB CORPORATION PTE LTD is a company incorporated under the laws of Singapore.)

NOTE: This Report is not a Certificate of Quality. It is issued subject to the "Terms and Conditions Governing Technical Services" set out in the "Request for Technical Services" form. The terms and conditions governing the issue of this report are set out overleaf.

Subject

IP RATING OF STAINLESS STEEL OVERGROUND BOX

Client

Spanners International Pte Ltd
6 Changi North Street 1
Singapore 498825

Attn: Mr Gemcee Lansangan

Sample Submission Date

2001-09-17

Description of Sample

Product type	:	Stainless Steel Overground Box
Trade name	:	Nil
Model	:	SP-SS-OGB.
Serial No.	:	Nil
Dimension	:	450 x 800 x 265mm
Manufacturer	:	Spanners International Pte Ltd
Country of origin	:	Singapore



This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to PSB Corporation or to the report or results furnished by PSB Corporation in any advertisements or sales promotion.

PSB Corporation Pte Ltd

Testing Group

1 Science Park Drive Singapore 118221 Tel 65 772 9620 Fax 65 775 9725 Email testing@psbcorp.com

Our Ref: 55S01491/KYM/THK

Method of Test

The assessment detailed in this document was carried out in accordance with clauses 13.4 (IP6X) and 14.2.5 (IPX5) of IEC 60529 : 1989.

Results

Clause No.	Title/Description	Results
13.4	Dust-tight (IP6X)	Complied
14.2.5	Protected against water jet (IPX5)	Complied

Remarks:

The Stainless Steel Overground Box submitted was deemed to comply with the requirements of IP65.



KWOK YEE MENG
TECHNICAL EXECUTIVE



TAN HENG KHOON
SENIOR ENGINEER
LIGHTING
TESTING GROUP

/my

Appendix II

Marking

